

Hello,

Our comments on your document:

1-No place is awarded to low-speed communication over powerline: is that intentional?

Did you forget a part of the industry?

2-BPL for applications in monitoring and metering is completely *overkill* in terms of technology & costs. It is much more efficient to use low-cost, low-bandwidth PLC solutions for these applications.

3-Implementing a technology in AMR that has a track-record and client lists is much more safe than implementing a do-it-all solutions that has not been proven.

We would very much like to know where the government stands in terms of low-bandwidth PLC solutions.

Best regards,

Francis Raveneau
Business Development Manager

Ariane Controls

www.arianecontrols.com

Tel.: +1.418.874.1919 x207

Cell.: +1.418.265.4296

Skype: raveneau

Yahoo Messenger: raveneau1