KNOW YOUR FIRE EXTINGUISHERS

	TYPE OF FIRE					Alberta	
		ORDINARY COMBUSTIBLES • wood	FLAMMABLE LIQUIDS • gasoline ELECTRICAL EQUIPMENT • motors		LABOUR Fire Commissioner's Office		
TYPE OF EXTINGUISHE	R	papercloth, etc.	paints (oil based)oils, etc.	switches	RANGE	HOW TO OPERATE	
	WATER PUMP TANK		NO	NO	9m to 12m	Place foot on footrest, pump handle and direct stream at base of flame.	
	STORED PRESSURE		NO	NO	9m to 12m	Pull pin, rupture cartridge if applicable, squeeze nozzle to release agent. Direct discharge at base of flames in a sweeping motion,	
co ₂		NO		K	1 m to 1.5 m	then direct it gradually forward or at remaining material that is burning.	
HALON		YES (If classification rating is IA or greater)			2.5m to 4.5m		
DRY CHEMICAL	ORDINARY	NO		5	1.5m to [°] 6m		
	MULT- PURPOSE				5m to 7.5m	NOTE: All extinguishers require annual servicing or servicing after use.	