

Test Your Smoke Alarms



Smoke Alarms in every home on every level save lives, but only if they're working properly!

Please test and maintain your smoke alarms.

Test

- Test your smoke alarms monthly with smoke.
 - Drift smoke from a just extinguished candle.
 - Alarm should sound within 20 seconds.
 - Fan smoke away to silence alarm.

If alarm does not sound:

Possible Causes

Action

- battery dead replace immediately
- no electricity check fuse box/breaker panel or refer to electrician
- smoke alarm dead replace immediately


Maintain

- Clean smoke alarms twice a year.
 - Remove and wipe cover with a damp cloth.
 - Gently vacuum the inside of the alarm.
- Replace batteries once a year or as needed.
- Never remove batteries for other uses.

Check off your monthly tests:

Jan	Feb	Mar
Apr	May	Jun
Jul	Aug	Sept
Oct	Nov	Dec

Date Battery replaced:



Alberta

MUNICIPAL AFFAIRS
Fire Commissioner's Office