

May 11, 2006

TABLE OF CONTENTS

PART 3 - LOCKOUT

	Page
DEFINITIONS	3-1
GENERAL.....	3-1
WHEN LOCKOUT REQUIRED.....	3-1
LOCKOUT PROCEDURES	3-1
GROUP LOCKOUT PROCEDURE.....	3-2
ACCESS TO ENERGY-ISOLATING DEVICES	3-2
CHECKING LOCKED OUT EQUIPMENT.....	3-3
REMOVAL OF LOCKS	3-3
LOCKS NOT REQUIRED	3-3

PART 3 – LOCKOUT

DEFINITIONS

3.01 In this part, the following definitions apply:

“control system”

means a manual, remote, automatic or partially automatic system for controlling the operation of equipment;

“energy-isolating device”

means a device that physically prevents the transmission or release of an energy source to machinery or equipment;

“energy source”

means any electrical, mechanical, hydraulic, pneumatic, chemical, thermal or other source of energy of potential harm to workers;

“isolating device”

means a device for controlling the operation of machinery or equipment;

“lockout”

means the use of a lock or locks to render machinery or equipment inoperable or use of an energy-isolating device in accordance with written procedures;

“personal lock”

means a lock provided by the employer for a worker to use for personal lockout protection such that each lock, when applied, is operable only by a key in the worker's possession, and by a key under the control of the supervisor or manager in charge.

GENERAL

Isolation

3.02 Where a worker could be injured by the unexpected energization or startup of machinery or equipment, or the unexpected release of an energy source, the energy source shall be isolated and effectively controlled.

WHEN LOCKOUT REQUIRED

Lockout required

3.03 Whenever machinery or equipment is shut down for maintenance work, all energy-related hazards shall be effectively controlled before work is done.

During maintenance

- (1) All parts and attachments shall be secured against inadvertent movement.
- (2) Energy-isolating devices shall be locked out as required by this Part.

Normal production

- (3) Where machinery or equipment is in use for normal production work and is not effectively safeguarded to protect the workers, lockout procedures shall be followed.

LOCKOUT PROCEDURES

Procedures

- 3.04**
- (1) Safe, effective lockout procedures, specific to the workplace, shall be developed and workers shall be trained in the safe and effective use of these procedures.
 - (2) Lockout procedures shall provide a safe, orderly transfer of control of the lockout at shift change or such other times as is necessary.

	(3) Lockout procedures shall be explained verbally and given in writing to each worker.
Number of locks	(4) A sufficient number of locks suitable to the lockout procedure shall be supplied to each worker.
Identification	(5) Each personal lock shall be marked so the worker who applied it can be easily identified.
Combination locks	(6) Combination locks shall not be used for lockout procedures.
Specified locks	(7) When an energy-isolating device is locked out, it shall be secured in the safe position with locks specified in the lockout procedure developed by the employer.
Application	(8) Every worker shall correctly apply lockout procedures.

GROUP LOCKOUT PROCEDURE

Procedures for group lockout	3.05 A group lockout procedure shall be developed and used where three or more workers are working on machinery or equipment that must be locked out, or when more than four energy-isolating devices require isolation. The procedure must meet the requirements of subsections (1) to (6).
Appointed workers	(1) Two competent and appointed persons shall be responsible for <ul style="list-style-type: none"> (a) independently locking out the energy-isolating devices, (b) securing the keys for the locks used under subsection (a) with personal locks or other positive sealing devices acceptable to the director, and (c) completing, signing and posting a checklist that identifies the machinery or equipment components covered by the lockout.
Personal locks	(2) Each worker, before commencing work on the locked out components, shall apply a personal lock to the key securing system used in subsection (1) (b).
Secondary system	(3) Workers shall lock out a secondary key securing system where two competent persons lock out the primary key securing system and place their keys in the secondary system.
Lock removal	(4) Each worker referred to in subsections (2) and (3) shall remove his or her personal lock from the key securing system on completion of the work.
Group removal	(5) When the requirements of subsection (4) have been met and it has been determined that it is safe to end the group lockout, the two competent persons shall be responsible for removing their personal locks or the positive sealing device from the key securing system containing the keys for the locks, and once those keys are released, the system shall no longer be considered locked out.
Written procedure	(6) The written group lockout procedure shall be conspicuously posted at the place where the system is in use.

ACCESS TO ENERGY-ISOLATING DEVICES

Access to devices	3.06 When an energy-isolating device is locked out, the lock shall not prevent access to other energy-isolating devices supplying machinery or equipment.
--------------------------	--

INDEX

PART 3 – LOCKOUT

	Page
ACCESS TO ENERGY-ISOLATING DEVICES	3-2
Access to devices.....	3-2
CHECKING LOCKED OUT EQUIPMENT	3-3
Verification of lockout	3-3
Worker responsibility	3-3
DEFINITIONS	3-1
GENERAL	3-1
Isolation	3-1
GROUP LOCKOUT PROCEDURE	3-2
Appointed workers.....	3-2
Group removal.....	3-2
Lock removal	3-2
Personal locks	3-2
Procedures for group lockout	3-2
Secondary system	3-2
Written procedure	3-2
LOCKOUT PROCEDURES	3-1
Application	3-2
Combination locks	3-2
Identification	3-2
Number of locks.....	3-2
Procedures	3-1
Specified locks.....	3-2
LOCKS NOT REQUIRED	3-3
No lockout required	3-3
REMOVAL OF LOCKS	3-3
Lock removal	3-3
WHEN LOCKOUT REQUIRED	3-1
During maintenance	3-1
Lockout required.....	3-1
Normal production	3-1