

December 6, 2004

### **Recall on Mobile Home Gas Furnaces**

The York International Corporation has recalled 226,000 mobile home propane and natural gas furnaces under the brand name of Coleman, Coleman Evcon and Red T. The Company claim the furnaces sold nationwide between 1995 and 2000 can overheat causing the heat exchanger to crack or burn through. The overheating can, in turn, burn through drywall and other combustibles near the furnace posing a fire and smoke hazard.

The Company received 27 reports of fires that could have been related to the furnaces, some of which resulted in extensive property damage. No injuries have been reported, but the Company warned that the problem, if left unresolved, could lead to personal injury or death.

Furnaces with the following model numbers are included in the recall:

DGAM075BDD  
DGAMO75BDE  
DGAMO75BDF  
DGATO70BDD  
DGATO70BDE  
DGATO70BDF  
DGATO75BDD  
DGATO75BDE  
DGATO75BDF  
DLASO75BDD  
DLASO75BDE  
DLASO75BDF

The model number is written on the nameplate, found by removing both front access panels. The nameplate is found mounted on the left inside surface behind the lower panel.

For more information, contact Ron McRae, Manager, Electrical/Mechanical Services at (867) 920-8801.