

**From Date**  
March 2, 2002

**To Date**  
March 8, 2002

**Approval No**  
00004529-00-00

**Approval Name**  
FRED'S WATERWORKS SYSTEM

### SUBMITTED DATA

Location	Parameter	Date	< or >	Value	Unit	Sample Type	Frequency	Count	Water Type	Reading Type	Method
DISTR. SYSTEM - RANDOM LOCATIONS	CHLORINE, FREE	8-Mar-02		0.1	mg/L	GRAB	WEEK	1	TREATED WATER.	n/a	UNKNOWN METHOD
DISTR. SYSTEM - RANDOM LOCATIONS	TURBIDITY	8-Mar-02		1	NTU	GRAB	WEEK	1	TREATED WATER.	n/a	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	CHLORINE, FREE	2-Mar-02		0.65	mg/L	GRAB	DAILY	1	TREATED WATER.	n/a	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	CHLORINE, FREE	3-Mar-02		0.7	mg/L	GRAB	DAILY	1	TREATED WATER.	n/a	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	CHLORINE, FREE	4-Mar-02		0.85	mg/L	GRAB	DAILY	1	TREATED WATER.	n/a	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	CHLORINE, FREE	5-Mar-02		0.8	mg/L	GRAB	DAILY	1	TREATED WATER.	n/a	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	CHLORINE, FREE	6-Mar-02		1.1	mg/L	GRAB	DAILY	1	TREATED WATER.	n/a	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	CHLORINE, FREE	7-Mar-02		1	mg/L	GRAB	DAILY	1	TREATED WATER.	n/a	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	CHLORINE, FREE	8-Mar-02		0.6	mg/L	GRAB	DAILY	1	TREATED WATER.	n/a	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	TURBIDITY	2-Mar-02		0.61	NTU	GRAB	DAILY	1	TREATED WATER.	n/a	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	TURBIDITY	3-Mar-02		0.2	NTU	GRAB	DAILY	1	TREATED WATER.	n/a	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	TURBIDITY	4-Mar-02		0.3	NTU	GRAB	DAILY	1	TREATED WATER.	n/a	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	TURBIDITY	5-Mar-02		0.3	NTU	GRAB	DAILY	1	TREATED WATER.	n/a	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	TURBIDITY	6-Mar-02		0.25	NTU	GRAB	DAILY	1	TREATED WATER.	n/a	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	TURBIDITY	7-Mar-02		0.3	NTU	GRAB	DAILY	1	TREATED WATER.	n/a	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	TURBIDITY	8-Mar-02		0.45	NTU	GRAB	DAILY	1	TREATED WATER.	n/a	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	VOLUME	2-Mar-02		138	M3	CONTINUOUS	DAILY	1	TREATED WATER.	TOT	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	VOLUME	3-Mar-02		120	M3	CONTINUOUS	DAILY	1	TREATED WATER.	TOT	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	VOLUME	4-Mar-02		95	M3	CONTINUOUS	DAILY	1	TREATED WATER.	TOT	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	VOLUME	5-Mar-02		150	M3	CONTINUOUS	DAILY	1	TREATED WATER.	TOT	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	VOLUME	6-Mar-02		148	M3	CONTINUOUS	DAILY	1	TREATED WATER.	TOT	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	VOLUME	7-Mar-02		160	M3	CONTINUOUS	DAILY	1	TREATED WATER.	TOT	UNKNOWN METHOD
ENTERING DISTRIBUTION SYSTEM	VOLUME	8-Mar-02		120	M3	CONTINUOUS	DAILY	1	TREATED WATER.	TOT	UNKNOWN METHOD
ENTERING TREATMENT PLANT	TURBIDITY	2-Mar-02		3.8	NTU	GRAB	DAILY	1	RAW WATER.	n/a	UNKNOWN METHOD
ENTERING TREATMENT PLANT	TURBIDITY	3-Mar-02		2.5	NTU	GRAB	DAILY	1	RAW WATER.	n/a	UNKNOWN METHOD
ENTERING TREATMENT PLANT	TURBIDITY	4-Mar-02		2.7	NTU	GRAB	DAILY	1	RAW WATER.	n/a	UNKNOWN METHOD
ENTERING TREATMENT PLANT	TURBIDITY	5-Mar-02		3	NTU	GRAB	DAILY	1	RAW WATER.	n/a	UNKNOWN METHOD
ENTERING TREATMENT PLANT	TURBIDITY	6-Mar-02		2.9	NTU	GRAB	DAILY	1	RAW WATER.	n/a	UNKNOWN METHOD
ENTERING TREATMENT PLANT	TURBIDITY	7-Mar-02		3.1	NTU	GRAB	DAILY	1	RAW WATER.	n/a	UNKNOWN METHOD
ENTERING TREATMENT PLANT	TURBIDITY	8-Mar-02		3.2	NTU	GRAB	DAILY	1	RAW WATER.	n/a	UNKNOWN METHOD
ENTERING TREATMENT PLANT	VOLUME	8-Mar-02		853	M3	CONTINUOUS	WEEK	1	RAW WATER.	TOT	UNKNOWN METHOD