

# Rural Water Quality and You – Individual Supplies

If you own or operate a water system, you are responsible for the quality of the water. Regular water quality testing is recommended.

### Water Quality on the Canadian Prairies

On the Canadian Prairies, water is obtained from surface sources (dugouts, lakes, reservoirs, ponds, rivers, etc.) and groundwater sources (wells and springs). Water from a particular source has its own unique quality characteristics. These characteristics can change slowly over time, or rapidly (sudden contamination event). The characteristics may also change in a cycle that matches the changing of the seasons. Surface water and shallow wells are more susceptible to seasonal changes and sudden contamination events than properly sited and constructed deep wells. Water quality within the same pipeline, household or farm distribution system may be different at various locations within each system (water quality can deteriorate in the pipes).

#### **Water Quality Characteristics and Effects**

Water quality is characterized by the organisms, chemicals and minerals that are suspended or dissolved in the water. Water that appears to be pristine may contain organisms, chemicals and/or minerals in concentrations that can be harmful to human health. Such concentrations can make the water unsuitable for domestic use, food processing or industrial applications, and be detrimental to farm applications (affecting livestock health and weight gain, pesticide performance,

clogging animal misters and boilers, etc.). Thus, regular water testing is essential.



Maintaining water quality can have beneficial implications for producers. Studies show that good water leads to greater gains in livestock.

## The Importance of Regular Water Quality Testing

Regular testing is required to ensure the quality of water from any source is appropriate for its intended use. The frequency of testing, and the characteristics of the water to be tested, depend on many factors (source quality, source variability, distribution system impacts and intended use). Any change in the odour, taste or appearance of your water may also be a signal to test your water.

Water can only be considered safe for drinking if it is tested on a regular basis for the appropriate organisms, chemicals and minerals. If the water has been contaminated, a more detailed water analysis will be required and testing frequency may increase. Water used for applications other than human consumption may have considerably different water testing requirements (e.g. testing for hardness for use in boilers).

Owners/operators of water systems will need to test the source water to determine the appropriate treatment for the water's intended use, and regularly test the water to ensure the source water quality has not changed and treatment is achieving the desired results. You should test the water throughout your distribution system to ensure the quality has not deteriorated. How a water quality sample is obtained is as important as how it is tested. For more information on water quality sampling and testing, please contact your local provincial health authority, or view PFRA's water quality fact sheets at:

http://www.agr.gc.ca/pfra/water/quality\_e.htm



#### **Protection of Water Supplies**

The protection of water supplies is the first step in improving or maintaining the quality of water obtained at the source. Proper protection of the water supply can greatly reduce treatment and monitoring requirements, as well as the risk of surface and groundwater contamination. Wastewater from humans or animals, hazardous chemicals, fuel, oil, pesticides and cleaning products must be properly managed to avoid contaminating a water supply. Other potential sources of contamination can be avoided by the safe application of fertilizers and proper management of soil erosion. Wells and dugouts should be strategically located to minimize the potential for contamination, and be operated and maintained properly.

For more information on the protection of water supplies, please see the Water Quality Matters – Agriculture Best Management Practices fact sheet located at: <a href="http://www.agr.gc.ca/pfra/water/quality\_e.htm">http://www.agr.gc.ca/pfra/water/quality\_e.htm</a>. The same website can be used to obtain information on wells and dugouts and/or to obtain copies of *Quality Farm Dugouts*.

## **Selection of Water Treatment Equipment**

A water treatment system must be designed to remove or control undesirable organisms, chemicals and minerals that are found in water. Before water treatment equipment is purchased, water should be tested and expert technical advice sought from several competent suppliers. One device will not solve all potential problems, and there are no universal treatment systems. The recommendations should be compared and the best process selected.

Water treatment systems and devices are presently not regulated in Canada. If certified water treatment equipment is desired, check for certification by National Sanitation Foundation (NSF) International. NSF International is an independent non-profit organization that is respected around the world. The NSF International web site is located at: <a href="http://www.NSF.org">http://www.NSF.org</a>

Certification of water treatment systems is based on "test" water. The "test" water may not contain all the same organisms, chemicals or minerals that a particular source water contains. As a result, the performance and maintenance of certified equipment may vary from expected values.



Water that appears to be pristine may contain harmful concentrations of organisms, chemicals and/or minerals, making it unsuitable for domestic use, and detrimental to farm applications. Regular water quality testing can prevent the possibility of dangerous concentrations building up in the water system.

## **Operation and Maintenance of Private Water Systems**

All water systems must be properly operated and maintained to obtain desirable water quality. This requires regular

inspection, backwashing, replacement of filters and worn parts in accordance with the recommendations of the supplier. Follow the recommendations of your supplier, but be prepared to customize operation and maintenance to suit the water being treated. There is no universal operation and maintenance regime.

Regular testing of water obtained from a treatment system is required to ensure the system is achieving the desired results. Treatment systems that are improperly designed or not operating properly can have a detrimental effect on the quality of water and put the user at risk.

## Water Quality Guidelines

Water quality guidelines for irrigation and livestock can be obtained from the Environment Canada Internet site at: <a href="http://www.ec.gc.ca/CEQG-RCQE/English/Ceqg/Water/default.cfm">http://www.ec.gc.ca/CEQG-RCQE/English/Ceqg/Water/default.cfm</a>



A regularly tested water treatment system means a glass of safe clean water.

Drinking water quality guidelines can be obtained at the Health Canada Internet site at: <a href="http://www.hc-sc.gc.ca/hecs-sesc/water/dwgsup.htm">http://www.hc-sc.gc.ca/hecs-sesc/water/dwgsup.htm</a>

Provincial governments are mandated to set drinking water quality standards. If you have questions regarding the safety of your drinking water, please contact your local provincial health authority.

## Role of Agriculture and Agri-Food Canada - PFRA

PFRA provides funding and technical assistance to rural clients for dugouts, wells, pipelines, other water supplies, water source protection and rural water quality. PFRA does not operate or maintain water supplies, test water or ensure the safety or adequacy of water for its intended use. Information on rural water quality and testing can be obtained at PFRA Offices, or on the Internet at <a href="http://www.agr.gc.ca/pfra/water/quality">http://www.agr.gc.ca/pfra/water/quality</a> e.htm

Remember, if you own or operate a private water system, you are responsible for the quality of the water and any treatment that is required to make the water suitable for its intended use. Regular water quality testing is recommended.